Voltage and Amperage Rectifier Readings

(for impressed current systems)

Month/Year Cathodic Protection System Installed:	/
--	---

	Amperes	Voltage	Date
Initial Rectifier Settings			
Rectifier Adjustment			
Rectifier Adjustment			

Report any change in voltage or amperage immediately to your supervisor and corrosion protection expert. Any change could indicate a problem with the cathodic protection system. All repairs or adjustments must be made by a corrosion expert as soon as possible.

Every 60 Day Meter Readings (monthly recommended)

-	Every 60 Day Meter Readings (monthly recommended) Date Amperes Voltage Name					
Date	Amperes	Voltage	Name			